

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50679091 0001

Berichtsnummer Report No.:

CN25GID3 001

Genehmigungsinhaber License Holder:

Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte Manufacturing Site:

Zhejiang Tengen Electric Co., Ltd.
(Yueqing Economic
Development Zone Branch)
No.288 Central Avenue
Development Zone, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

EN 60898-1:2019+A1+A11

Geräteidentifikation
Product Identification
Produkt:

Circuit Breaker

Product:

(Miniature Circuit-breaker)

Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Technische Daten auf nächste(r) Seite(n) gelistet

Technical Data:

Technical Data is listed on the next page(s)

Gültig ab:

2025-06-13

Valid from:
Zertifizierungsstelle:

Certification body:

Ausstellungsdatum:

2025-06-13

Date of issue:

Wencai Zhang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com
TÜVRheinland®
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50679091 0001

Berichtsnummer *Report No.:*

CN25GID3 001

Produkt *Product:* Circuit Breaker
(Miniature Circuit-breaker)

Modell *Type:* **Bezeichnung** *Designation:*
Type Designation : TGB3-40

Trade Mark : Tengen(Logo)

Rated Operation Voltage (Ue): 220/230/240V~ (1P+N)
 Rated Current (In) : 6/10/16/20/25/32/40A
 Pollution Degree : 2
 Reference Ambient Air Temperature : +30°C
 Rated Frequency : 50/60Hz
 Instantaneous Tripping Current : B-/C-/D-Type
 Rated Service Short-circuit Capacity (Ics) : 6000A
 Rated Short-circuit Capacity(Icn) : 6000A
 Impulse Withstand Voltage (Uimp) : 4.0kV
 Degree of Protection : IP20
 Rated Insulation Voltage (Ui) : 500V
 Suitability of Isolation : Yes

ANLAGE (Appendix): 1

